

## FACILITIES CLOSED DUE TO MOLD

- 1) Weitchpec Elementary School
  - a. The Entire School
    - i. Students will be transported to the school closest to their residence...all Intra-district Transfers will be revoked and students will return to their school of residence
    - ii. Staff will be transferred accordingly
- 2) Orleans Elementary School
  - a. All Classrooms--2, 3, 4 and 5
  - b. Four Portable Classrooms will be brought in as temporary student classrooms
- 3) Hoopa Valley Elementary School
  - a. 10 Classrooms
    - i. Rooms 15, 16, 17, 18, 19, 20, 21, 22, 23 and 24
    - ii. The Learning Center
    - iii. All 'other' rooms in that wing
- 4) Hoopa Valley High School
  - a. Welding Shop C400 and all 'other' rooms in that wing
  - b. Auto Shop C300 and all 'other' rooms in that wing
  - c. Wood Shop and Band Room C302 and C304 and all 'other' rooms in that wing
  - d. 11 Classrooms
    - i. Rooms C200, C201, C202, C203, C204, C205, C206, C207, C208, C209 and C210
    - ii. 12 Portable Classrooms will be brought in as temporary student classrooms
- 5) Trinity Valley Elementary School
  - a. The Library Media Center, the temporary school office, the staff workroom and all 'other' rooms in that wing

*Immediate remediation of the structures listed above is necessary. This judgment is based on laboratory confirmation as well as physical confirmation of clinically significant fungal surface contamination found on surfaces where water stains and visible mold/fungal contamination are present. Furthermore, the roofing, the plywood, the sheetrock ceiling, insulation, ceiling tiles and wall materials throughout the structure where water intrusions occurred shall be treated as mold infested based on the sample results and visual observations. The following recommendations for remediation shall be followed. An experienced competent mold abatement contractor shall perform all mold remediation activities. Air monitoring for mold, asbestos and lead shall occur from the start of the project until the completion. EPA, CARB and CAL/OSHA requirements shall be followed for the asbestos portion of this project. Department of Health Services guidelines as well as CAL/OSHA guidelines shall be followed for all lead removal. Asbestos and lead specifications have been written to address the asbestos and lead issues.*